



XCelerator® XP Inspection and Maintenance Guide

XCelerator XP Stormwater Treatment System

The XCelerator High Performance Stormwater Treatment System (XP) is a hydrodynamic separator designed and supplied by AquaShield™, Inc. (AquaShield). The XP removes pollutants including suspended solids and debris from stormwater runoff by forcing flows downward from the inlet and then forced upward through an array of inclined plates. This design encourages particles to settle onto the surfaces of the inclined plates and accumulate at the bottom of the chamber.

The long-term performance of any stormwater treatment structure depends on a consistent maintenance plan. With XP, both treatment and storage are accomplished in the single treatment chamber without the use of multiple or hidden blind access chambers. This allows inspection and maintenance to be performed from the surface, eliminating confined space entry.

Inspection and Maintenance Frequency

In most cases, AquaShield recommends in most cases that a quarterly inspection for the first year of operation to develop an appropriate schedule of maintenance. Sites with higher volumes of wind-blown debris, and hydrocarbons, may require increased inspection and maintenance. Based on experience of the system's first year in operation, we recommend that the inspection schedule be revised to reflect the site-specific conditions encountered. Typically, the inspection schedule for subsequent years is reduced to semi-annual inspections.

The table below lists the available XP models as well as their inner diameters and the sediment storage capacities for systems constructed of polymer coated steel (PCS).

Aqua-Swirl Model	Inner Diameter (ft)	Sediment Storage Capacity (ft ³)
XP-2	2.5	6
XP-3	3.5	12
XP-4	4.5	19
XP-5	5.5	29
XP-6	6.5	40
XP-7	7.5	53
XP-8	8.5	68
XP-9	9.5	85
XP-10	10.5	104
XP-11	11.5	125
XP-12	12.5	147
XP-13	13.0	159

XCelerator XP Inspection Procedure

To inspect the XP unit, a hook is typically needed to remove the manhole cover. Within the riser, a metal plate provides our contact information, the XP model size, and serial number.

The only tools needed to inspect the XP unit are a flashlight and a measuring device. From the surface, the inspector can observe any floating oil and debris. To measure sediment depths, lower the measuring device to the top of the sediment pile. Keep in mind that the finer sediment at the top of the pile may offer less resistance to pressure.


AquaShield recommends that the units be cleaned when sediment depth reaches 7.25 inches, representing 50% sediment storage capacity.

XCelerator XP Cleanout Procedure

Cleaning the XP unit is simple and quick. Free-floating oil and floatable debris can be removed directly through the 30-inch service access. A vacuum truck is typically used to remove the accumulated sediment and debris. Since there are no multiple or limited (blind) access chambers in the XP, there are no restrictions to impede on-site maintenance tasks.

Disposal of Recovered Materials

AquaShield recommends that all maintenance activities be performed in accordance with appropriate health and safety practices for the tasks and equipment being used. All material removed during maintenance shall be handled and disposed of in full accordance with any applicable local and state requirements.



XP Unit Access Diagram

XCelerator XP Inspection and Maintenance Worksheets on following pages.

AquaShield Contact Information

AquaShield, Inc.
2733 Kanasita Dr #111, Hixson, TN 37343
Toll free (888) 344-9044
Phone: (423) 870-8888
Email: info@aquashieldinc.com
Web: www.aquashieldinc.com

XCelerator XP Inspection Worksheets



SITE and OWNER INFORMATION

Site Name: _____ Date / Time: _____
Site Location: _____
Inspector Name: _____
Inspector Company: _____ Phone #: _____
Owner Name: _____ Phone #: _____
Owner Address: _____

INSPECTIONS

I. Floatable Debris and Oil

1. Remove manhole lid to expose liquid surface of the XP unit.
2. Remove floatable debris with basket or net if any present.
3. If oil is present, measure its depth. Clean liquids from system if one half ($\frac{1}{2}$) inch or more oil is present.

Note: Water in XCelerator XP can appear black and similar to oil due to the dark body of the surrounding structure. Oil may appear darker than water in the system and is usually accompanied by oil-stained debris (e.g. Styrofoam, etc.). The depth of oil can be measured with an oil/water interface probe, a stadia rod with water finding paste, a coliwasa, or collect a representative sample with a jar attached to a rod.

II. Sediment Accumulation

1. Lower measuring device (e.g. stadia rod) into swirl chamber through service access provided until top of sediment pile is reached.
2. Record distance to top of sediment pile from top of standing water: _____ inches.
3. Maximum recommended sediment depth prior to cleanout is 7.25 inches for all models. Consult system shop drawing for treatment chamber depth as measured from the inlet pipe inverted to base of the unit.

III. Diversion Structures (External Bypass Features)

If a diversion (external bypass) configuration is present, it should be inspected as follows:

1. Inspect weir or other bypass features for structural decay or damage. Weirs are more susceptible to damage than off-set piping and should be checked to confirm that they are not crumbling (concrete or brick) or decaying (steel).
2. Inspect diversion structure and bypass piping for signs of structural damage or blockage from debris or sediment accumulation.
3. When feasible, measure elevations on diversion weir or piping to ensure it is consistent with site plan designs.
4. Inspect downstream (convergence) structure(s) for sign of blockage or structural failure as noted above.

CLEANING

Schedule cleaning with local Vactor company to remove sediment, oil and other floatable pollutants. The captured material generally does not require special treatment or handling for disposal. Site-specific conditions or the presence of known contaminants may necessitate appropriate actions be taken to clean and dispose of materials captured and retained by the XP unit. All cleaning activities should be performed in accordance with property health and safety procedures.

AquaShield always recommends that all materials removed from the XP unit during the maintenance process be handled and disposed of in accordance with local and state environmental or other regulatory requirements.

MAINTENANCE SCHEDULE

I. During Construction

Inspect the XP unit every three (3) months and clean the system as needed. The XP unit should be inspected and cleaned at the end of construction regardless of whether it has reached its maintenance trigger.

II. First Year Post-Construction

Inspect the XP unit every three (3) months and clean the system as needed. Inspect and clean the system once annually regardless of whether it has reached its sediment or floatable pollutant storage capacity.

III. Second and Subsequent Years Post-Construction

If the XP unit did not reach full sediment or floatable pollutant capacity in the First Year Post-Construction period, the system can be inspected and cleaned once annually.

If the XP unit reached full sediment or floatable pollutant capacity in less than 12 months in the First Year Post-Construction period, the system should be inspected once every six (6) months and cleaned as needed. The XP unit should be cleaned annually regardless of whether it reaches its sediment or floatable pollutant capacity.

IV. Bypass Structures

Bypass structures should be inspected whenever the XP unit is inspected. Maintenance should be performed on bypass structures as needed.

AquaSwirl Maintenance Worksheets



MAINTENANCE COMPANY INFORMATION

Company Name: _____
Street Address: _____
City: _____ State/Prov.: _____ Zip/Postal Code: _____
Contact: _____ Title: _____
Office Phone: _____ Cell Phone: _____

ACTIVITY LOG

Date of Cleaning: _____ Time of Cleaning: _____
Date of Next Inspection: _____ Floatable debris present: Yes No
Oil present: Yes No Oil depth (inches): _____ Measurement Method: _____

STRUCTURAL CONDITIONS and OBSERVATIONS

Structural damage: Yes No Where: _____
Structural wear: Yes No Where: _____
Odors present: Yes No Describe: _____
Clogging: Yes No Describe: _____

NOTES

Additional Comments and/or Actions To Be Taken

Time Frame

ATTACHMENTS

- Attach site plan showing XP unit location.
- Attach detail drawing showing XP unit dimensions and model number.
- If a diversion configuration is used, attach details showing basic design and elevations (where feasible).

TABULAR MAINTENANCE SCHEDULE

Date Construction Started: _____ Date Construction Ended: _____

DURING CONSTRUCTION

Activity	Month											
	1	2	3	4	5	6	7	8	9	10	11	12
Inspect and Clean as needed			X			X			X			X
Inspect Bypass as needed			X			X			X			X
Clean System*												X*

* The AquaSwirl should be cleaned at least once a year during construction. Additionally, the system should always be cleaned at the end of construction.

FIRST YEAR POST-CONSTRUCTION

Activity	Month											
	1	2	3	4	5	6	7	8	9	10	11	12
Inspect and Clean as needed			X			X			X			X
Inspect Bypass as needed			X			X			X			X
Clean System*												X*

* The AquaSwirl should be cleaned at least once during the first year.

Second and Subsequent Years Post-Construction

Activity	Month											
	1	2	3	4	5	6	7	8	9	10	11	12
Inspect and Clean as needed												X*
Inspect Bypass, as needed												X*
Clean System*												X*

* If the AquaSwirl did not reach full pollutant capacity in the First Year Post-Construction period, the system can be inspected and cleaned annually. If the AquaSwirl reached full pollutant capacity in less than 12 months in the First Year Post-Construction period, the system should be inspected once every six (6) months or more.